## **VENTILATION SYSTEM OVERVIEW**

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	59 - Peace River South
School Name:	Crescent Park Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes Date of last inspection: 2023-08-21 Date of next inspection: 2023-09-08 Date and type of most recent maintenance: Filter and operational inspection.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail: Manual control, require seasonal adjustment
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes Detail (Including filter grade): Merv 13 filters all Furnaces
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: No Detail:
Other Relevant Information:	new system completed 2018 3 forced air furnaces .
District Contact for any Questions:	Name: Wade Simlik   Phone Number: (250) 782-2417   Email: wsimlik@sd59.bc.ca

VENTILATION SYSTEM OVERVIEW | SEPTEMBER 2021